

Week Ending	Alkalis (NaEq)	SO ₃	45-micron Residue	Fineness	Initial Set	Final Set	Soundness	Water	LOI	I-3D	I-7D	I-28D
	%	%	%	m ² /kg	minutes	minutes	mm	%	%	MPa	MPa	MPa
02/03/2026	0.50	2.7	5.40	361	120	210		28.0	2.9	38.6		
23/02/2026	0.49	2.6	5.00	370	105	210	1	28.0	2.8	38.6	54.3	69.5
16/02/2026	0.49	2.6	5.70	385	105	210	2	28.0	2.7	39.5	54.8	70.1
09/02/2026	0.46	2.6	4.80	388	120	195	1	28.2	2.7	40.0	53.6	65.8
04/02/2026	0.50	2.4	3.90	375	120	195	2	28.9	2.6	41.2	58.2	72.9
28/01/2026	0.53	2.4	3.90	342	105	210	2	28.3	2.7	40.8	56.0	69.5
14/01/2026	0.47	2.4	3.50	383	90	180	1	28.3	2.8	39.9	55.3	70.3
07/01/2026	0.41	2.3	5.50	382	105	195	1	27.7	3.1	39.3	55.0	69.0
22/12/2025	0.41	2.6	4.4	362	105	195	1	28.7	3.2	36.3	52.9	70.0
15/12/2025	0.41	2.5	4.1	375	120	210	0	28.8	3.0	40.4	57.3	71.3
08/12/2025	0.45	2.5	3.8	374	105	210	0	28.2	3.1	40.5	57.0	73.6
01/12/2025	0.46	2.5	3.9	369	105	195	2	28.2	2.9	41.2	57.5	74.1
26/11/2025	0.44	2.5	4.7	370	105	210	2	28.2	3.0	40.6	58.0	74.7
17/11/2025	0.44	2.5	4.2	378	90	210	3	28.2	3.1	40.1	56.6	71.2
10/11/2025	0.43	2.5	3.4	376	90	210	1	28.3	2.9	40.1	56.4	71.0
03/11/2025	0.44	2.7	4.2	381	105	210	2	28.3	3.1	39.6	55.1	71.0
24/10/2025	0.45	2.7	3.4	375	120	210	1	28.3	2.7	40.4	56.4	72.4
17/10/2025	0.44	2.9	3.6	396	90	180	1	28.8	3.1	41.1	58.9	68.1
10/10/2025	0.44	2.8	3.5	386	120	210	1	28.8	3.5	37.6	55.1	71.0
03/10/2025	0.43	2.8	4.3	391	105	195	1	28.8	3.1	38.6	53.3	67.9
Min	0.41	2.3	3.4	342	90	180	1	27.7	2.6	36.3	52.9	65.8
Max	0.53	2.9	5.7	396	120	210	3	28.9	3.5	41.2	58.9	74.7
Mean	0.45	2.6	4.3	376	107	203	1	28.4	3.0	39.7	55.9	70.7
StdDev	0.03	0.16	0.7	12.1	10.8	10.3	0.6	0.34	0.22	1.26	1.71	2.24
AS/NZS 2350:2006	0.64	3.5			45	360	5				35.0	45.0
Specifications	maximum	maximum			minimum	maximum	maximum				minimum	minimum
<p>HR Cement Ltd is registered for the production & distribution of cement in accordance with ISO 9001:2015. Xtra-Cem is tested in accordance with AS/NZS 2350 & NZS 3122:2009 Samples tested as received. This Test Report may not be reproduced except in full. Testing conducted by Cement Australia (Darra, Brisbane, Australia). Nata Accreditation Numbers: 187, 188</p>												
												
Dave Chater - Technical Manager (dave.chater@hrcl.co.nz)				Issue Date: 30/03/2026				Report ID: HRC-Xtra-cem 2026-WK13				